


KOGAION V1.09

KOGAION is a computer model application that simplifies the task of designing distributed renewable energy generation systems - both on and off-grid. It doesn't cover biofuel, hydrogen domains. KOGAION's optimization and sensitivity analysis algorithms allow you to evaluate the economic and technical feasibility of a photovoltaic, wind and hydro turbines technology options and to account for variations in technology costs and energy resource availability. Kogaion was designed at the IPA in 2010, and is permanently developed and enhanced according with the Romanian rules and laws regarding incentives for renewable.

KOGAION provides the detailed simulation and optimization in a model that is relatively simple and easy to use. It's adaptable to a wide variety of projects like wind, photovoltaic and hybrid for large on grid projects or small hybrid isolated projects (for a village, community-scale power system or individual system). KOGAION can model both the technical and economic factors involved in the project. For larger systems, KOGAION can provide an important overview that compares the cost and feasibility of different configurations.



KOGAION is accessible to large kind of users, including financial decision makers. Time references simulation is crucial for modeling variable resources, such as wind power. More than other software application Kogaion supports all kind of wind description (Weibul, pdf, TS). KOGAION's sensitivity analysis helps determine the potential impact of uncertain factors wind speed on a given system, over time. KOGAION models and simulations are referring to:

Renewable potential estimation:

- wind
- solar

Energy yield:

- solar photovoltaic (PV)
- wind turbine
- run-of-river hydro power

Data base:

- panels, turbines, batteries, inverters, chargers

Loads:

- electric utility with daily profiles
- "on grid"

Storage:



- pumping water
- battery bank

Hybrid system CAD:

- chain equipment verification

Economical outputs

The user interfaces are organized on 6 chapter, as it can be seen forward:





ENERGY ESTIMATION

Estimari din Serii de Timp

Estimare energie din S.T. la H_{turbina} dif de H_{masura}

Doua turbine diferite in aceiasi locatie

O turbina in 2 locatii diferite din S.T.

Estimari din descriere Weibull

Estimare energie din coef. Weibull

Estimare energie din W cu turbina in locatii dif

Calc. ec. pe intervalul de incertitudine a CV

C. ec. pe intervalul de incertitudine cu corectie de inflatie

Calcul economic - turbina

Calcul economic comparativ. Locatii multiple

Inapoi



Small hybrid renewable systems design





Curba de consum

Configurator sistem hibrid izolat

Configurator sistem hibrid

Baza de date pentru sisteme hibride

Inapoi



Forward there are presented several design interfaces to outline the Kogaion possibilities:

10-Oct-2011

Comparatie normalizata intre turbine


Inapoi

Tiparire

Comparare

turb 1: turb 2: turb 3: turb 4:

Funcția de transfer P/V pt turbinele: acsav29 , eolis , V100 , sciroco



10-Oct-2011

generare

NOTE

1. Se poate selecta un fisier cu Radiatia Solara din baza de date sau se pot aduce fisiere din aplicatia PVGIS
2. daca se opteaza pt date din PVGIS dupa aparitia ferestrei web JRC se selecteaza optiunea "Monthly radiation"
3. se selecteaza locatia dorita pe harta afisata in fereastra web
4. se selecteaza (exclusiv) optiunile "Horizontal" Irradiatin, "opt. angle" si "chosen angle" si esirea "Text file"
5. se inscrie unghiul de 90 grade in fereastra din dreapta optiunii 3 (chosen angle)
6. se apasa butonul "Calculation" si apare o fereastra noua care ne cere locatia si numele fisierului generat
7. numele fisierului bt e bine sa fie de genul "RSlocatie", daca nu operatiunile trebuiesc facute cu atentie
8. se verifica, cu Notepad-ul, daca val. numerice sunt toate aliniate in col.2; daca nu se scot tab-urile suplimentare
9. daca operatiunile 2-7 dureaza mult, dupa salvarea fisierului locatiei alese se mai apasa odata butonul "generare"
10. atat procesarea de date propriu-zisa cat aducerea de noi fisiere de date PVGIS se poate repeta la nesfarsit

3Feleac(saf)


Radiatie solara kwh/mp/zi - medie anuala

Est. e.el. prod/ an kwh/mp/an la 14% ef.ps si 75% ef. inst. el.

radiatia in kwh/mp/zi - medie lunara

| luna | oriz | optim | vert |
|--------|-------|-------|------|
| 1 Ian | 1.05 | 1.58 | 1.54 |
| 2 Feb | 1.81 | 2.56 | 2.31 |
| 3 Mar | 3.06 | 3.88 | 3.05 |
| 4 Apr | 4.42 | 4.86 | 3.06 |
| 5 Mai | 5.36 | 5.32 | 2.78 |
| 6 Iun | 5.78 | 5.48 | 2.57 |
| 7 Iul | 5.68 | 5.53 | 2.7 |
| 8 Aug | 5.04 | 5.4 | 3.11 |
| 9 Sep | 3.5 | 4.19 | 3.03 |
| 10 Oct | 2.42 | 3.5 | 3.12 |
| 11 Noi | 1.48 | 2.48 | 2.53 |
| 12 Dec | 0.888 | 1.37 | 1.37 |

Radiatia solara medie zilnica pe luni [kwh/mp]




Octavian Capatina

tiparire

inapoi

10-Oct-2011

Extragere coef. W., densit. putere din S.T.




SACUIEU 1100 6.5 50 10 2008 sacuiEU50 sacuiEU50
 Locatie Alitudine Temperatura h mas T.esant.(min) Perioada viteza vant directie vant

Generare


A(m/s)= 5.97 K= 1.69

Tiparire


Roza vanturilor la SACUIEU, altit. 1100m, h. mas. 50m, din 2008




Distrib. vantului la SACUIEU, altit. 1100m, h mas.= 50m, din 2008



Energia vantului/mp: 1656KWh, pe durata: 8760ore



Densitatea de putere a vantului: 189W/mp,




Octavian Capatina

Inapoi

10-Oct-2011

Vant, locatie, turbina, costuri, venituri, VNA, RIR





Turbina SACUIEU 100 7 100 50 6.82 1.69 0.4
 locatia altitudine temp / an h butuc h masura fac. scara coef. forma Dim. obst
V100 1.2 30 1.3 0.15 20 5 52 54.6 2012
 cost echip % instalare % O&M cost autoriz durata pr rata disc pret MWh pret CV an PIF
 euro/w din valoarea turbinei euro/w durata de stimulare cf L220 modif: 15ani

Tiparire

Generare

Inapoi



| anul | VNA(mii e... |
|----------|--------------|
| 1 an PIF | -3078.0 |
| 2 | 1.0 -2421.5 |
| 3 | 2.0 -1796.26 |
| 4 | 3.0 -1200.79 |
| 5 | 4.0 -633.68 |
| 6 | 5.0 -93.58 |
| 7 | 6.0 420.81 |
| 8 | 7.0 910.7 |
| 9 | 8.0 1377.26 |
| 10 | 9.0 1821.61 |
| 11 | 10.0 2244.79 |
| 12 | 11.0 2647.83 |
| 13 | 12.0 3031.67 |
| 14 | 13.0 3397.23 |
| 15 | 14.0 3745.39 |
| 16 | 15.0 4076.97 |
| 17 | 16.0 4220.42 |
| 18 | 17.0 4357.04 |
| 19 | 18.0 4487.15 |
| 20 | 19.0 4611.07 |
| 21 | 20.0 4729.09 |

Octavian Capatina

Put turb. [Kw]

cost initial (mii)

fact capacitate %

energie MWh/an

pret integral/Mwh

Venit net/an (mii)

RIR [%]

recuperare [ani]

recuperare act [ani]

RVC

Configurator sistem hibrid izolat - EFARM

locatie:

Altitudine [m]: 100

Temp medie/an [C]: 10

Radiatie[kwh/mp/z]: 3.3

cadere [m]: 2

debit [l/s]: 33

A [m/s]: 3.5

k: 1.7

h butuc [m]: 10

h butuc [m]: 15

obstacol echiv [m]: 0.2

10-Nov-2011

pret/w: 1.1 pret/w: 0.28 pret/w: 2 pret/w: 2 pret/Ah: 1.3 pret/w: 0.7

nr p sol in serie: 2 nr incarc: 1 nr t hidro: 1 nr t vant: 1 nr bat in serie: 4 nr inv: 1

nr serii in II: 4

generare

tiparire

inapoi

spre calcul economic

| turb vant | | tip panou | | turb hidro | | incarcator | | tip bat | | tip inv | |
|-------------|-------|-------------|--------|--------------|------|-----------------|-------|--------------|-------|-------------|-------|
| SVT20 | | CQ195M | | LH1k-48 | | TS60-48V | | rombat10... | | SISk-48 | |
| 1 P [Kw] | 20.0 | 1 P [w] | 195.0 | 1 P [kw] | 1.0 | 1 P [kw] | 3.2 | 1 C(20h)[Ah] | 100.0 | 1 P[Kw] | 5.0 |
| 2 Diam [m] | 12.35 | 2 Ue [V] | 36.74 | 2 hmin [m] | 0.6 | 2 Tps min [V] | 0.0 | 2 C(5h)[Ah] | 80.0 | 2 Ui min[V] | 41.0 |
| 3 h but [m] | 30.0 | 3 Ie [A] | 5.65 | 3 hmax [m] | 3.0 | 3 Tps max [...] | 150.0 | 3 Tens [V] | 12.0 | 3 Ui max[V] | 63.0 |
| 4 rand [%] | 90.0 | 4 Ugol [V] | 45.5 | 4 Dmin [l/s] | 30.0 | 4 Ipmax [A] | 60.0 | 4 lung [mm] | 329.0 | 4 Ue[V] | 230.0 |
| 5 Ue [V] | 400.0 | 5 efic. [%] | 15.27 | 5 Dmax [l/s] | 63.0 | 5 Tbat [V] | 48.0 | 5 lat [mm] | 172.0 | 5 THD [%] | 3.0 |
| 6 Utr [Kv] | 0.0 | 6 lung[mm] | 1580.0 | 6 Ue [V] | 48.0 | 6 Tbatmin [V] | 8.0 | 6 inal[mm] | 215.0 | 6 frecv[Hz] | 50.0 |
| 7 fr [Hz] | 50.0 | 7 lat [mm] | 808.0 | 7 frecv[Hz] | 0.0 | 7 Tbatmax [V] | 72.0 | 7 greut[kg] | 22.0 | 7 rand [%] | 95.0 |
| 8 P(3.5) | 1.0 | 8 gros[mm] | 50.0 | 8 rand [%] | 90.0 | 8 rand [%] | 99.0 | | | | |
| 9 P(4.5) | 2.0 | | | | | | | | | | |
| 10 P(5.5) | 4.0 | | | | | | | | | | |
| 11 P(6.5) | 7.0 | | | | | | | | | | |
| 12 P(7.5) | 11.0 | | | | | | | | | | |
| 13 P(8.5) | 16.0 | | | | | | | | | | |
| 14 P(9.5) | 20.0 | | | | | | | | | | |
| 15 P(10.5) | 20.0 | | | | | | | | | | |
| 16 P(11.5) | 20.0 | | | | | | | | | | |
| 17 P(12.5) | 20.0 | | | | | | | | | | |
| 18 P(13.5) | 20.0 | | | | | | | | | | |
| 19 P(14.5) | 20.0 | | | | | | | | | | |
| 20 P(15.5) | 20.0 | | | | | | | | | | |
| 21 P(16.5) | 20.0 | | | | | | | | | | |
| 22 P(17.5) | 20.0 | | | | | | | | | | |

KW inst: solara 1.56 hidro 1 vant 20

MWh/an: E. solara 1.88 E. hidro 5.1 E. vant 18.5

Asig max: 0.99 C m [kwh/z]: 64.5 E m [kwh/z]: 63.97

Ecc. produsa: 5.1 E.ca livrata: 23.35 C bat [kvah]: 7.68 I. e. [zile]: 0.12

Cadere [m]: 3

Debit [l/s]: 80

Ueps=Uiinc: 100

Tens. mag. cc[V]: 80

Puteri cc [kW]: 15

E&Cmed/z kWh: 80

Suma consum diurn - ATELIER

Octavian Capatina

tiparire

Eficienta economica a sistemului hibrid izolat - EFARM

locatie:

Altitudine [m]: 100

Temp medie/an [C]: 8

Radiatie[kwh/mp/z]: 3.32

cadere [m]: 2

debit [l/s]: 40

A [m/s]: 4.05

k: 1.7

h butuc [m]: 15

obstacol echiv [m]: 0.4

10-Oct-2011

euro/Mwh: 52 euro/CV: 57 an PIF: 2012

nr CV: 6 nr CV: 1 nr CV: 1.33

pret/w: 1.03 pret/w: 2 pret/w: 2.3

% inv s: 70 % inv h: 40 % inv v: 70

nr p sol in serie: 1 nr t hidro: 1 nr t vant: 1

nr serii in II: 2

prea datele din config

tiparire

| turb vant | | tip panou | | turb hidro | | tip bat | | tip bat | | tip inv | |
|----------------|------|----------------|--------|----------------|------|-------------|------|--------------|-------|-------------|-------|
| [L.java.lan... | | [L.java.lan... | | [L.java.lan... | | ninca | | ntbat | | ntinv | |
| 1 P [Kw] | 1.0 | 1 P [w] | 250.0 | 1 P [kw] | 1.0 | 1 P[kw] | 3.0 | 1 C(20h)[Ah] | 100.0 | 1 P[Kw] | 3.0 |
| 2 Diam [m] | 2.8 | 2 Ue [V] | 24.0 | 2 hmin [m] | 0.6 | 2 Upmin[V] | 30.0 | 2 C(5h)[Ah] | 80.0 | 2 Ui min[V] | 21.0 |
| 3 h but [m] | 6.0 | 3 Ie [A] | 7.23 | 3 hmax [m] | 3.0 | 3 Upmax[V] | 45.0 | 3 Tens [V] | 12.0 | 3 Ui max[V] | 30.0 |
| 4 rand [%] | 0.0 | 4 Ugol [V] | 43.8 | 4 Dmin [l/s] | 30.0 | 4 Ipmax[A] | 60.0 | 4 lung [mm] | 329.0 | 4 Ue[V] | 230.0 |
| 5 Ue [V] | 48.0 | 5 efic. [%] | 12.91 | 5 Dmax [l/s] | 63.0 | 5 Ucc [V] | 24.0 | 5 lat [mm] | 172.0 | 5 THD [%] | 3.0 |
| 6 Utr [Kv] | 0.0 | 6 lung[mm] | 1956.0 | 6 Ue [V] | 24.0 | 6 Ubat m[V] | 21.0 | 6 inal[mm] | 215.0 | 6 frecv[Hz] | 50.0 |
| 7 fr [Hz] | 0.0 | 7 lat [mm] | 990.0 | 7 frecv[Hz] | 0.0 | 7 Ubat M[V] | 30.0 | 7 greut[kg] | 22.0 | 7 rand [%] | 90.0 |
| 8 P(3.5) | 0.05 | 8 gros[mm] | 50.0 | 8 rand [%] | 90.0 | 8 efic. [%] | 90.0 | | | | |
| 9 P(4.5) | 0.15 | | | | | | | | | | |
| 10 P(5.5) | 0.25 | | | | | | | | | | |
| 11 P(6.5) | 0.4 | | | | | | | | | | |
| 12 P(7.5) | 0.6 | | | | | | | | | | |
| 13 P(8.5) | 0.8 | | | | | | | | | | |
| 14 P(9.5) | 1.1 | | | | | | | | | | |
| 15 P(10.5) | 1.4 | | | | | | | | | | |
| 16 P(11.5) | 1.42 | | | | | | | | | | |
| 17 P(12.5) | 1.2 | | | | | | | | | | |
| 18 P(13.5) | 1.05 | | | | | | | | | | |
| 19 P(14.5) | 1.0 | | | | | | | | | | |
| 20 P(15.5) | 0.73 | | | | | | | | | | |
| 21 P(16.5) | 0.5 | | | | | | | | | | |
| 22 P(17.5) | 0.2 | | | | | | | | | | |

C m [kwh/z]: 6.15 E m [kwh/z]: 19.86 Asig max: 3.22 C bat [kvah]: 1.92 I. e. [zile]: 0.31

Energie [MWh] pe an: solara 0.61 hidro 6.19 vant 1.26

Ecc prod. / an [MWh]: 8.06 E.ca livrata / an [MWh]: 7.25

cost investitie [euro]: 736 5000 3286 33 289 867

Cost inv. [euro]: 10211

cost investit/kwh prod. in 15 ani: 0.121 0.054 0.261

euro / kwh livrati: 0.141

Termen de recuperare fara CV [ani]: 27.08

Termen de recuperare cu CV [ani]: 10.54

calculat pe 15ani (cf. L.220/2008)

inapoi la config

10-Oct-2011

Parc solar cu orientare fixa, VNA, RIR, Rol




Put. parc kW: 100000 locatie: Feleac lat: lon: R.solara: 3.85 modul solar: CS6P240 Put ms W: 240 arie ms mp: 1.61 efic. ms %: 14.9

Cost echip. 1.5 euro/w % instalare 6 din valoarea panourilor % O&M 1.5 cost autoriz. 0.15 euro/w durata pr 20 rata actualiz 5 pret MWh 52 pret CV 50 nr CV 4

Tiparire

Generare

x 10⁵ VNA(mii euro) la o rata de actualizare = 5%



Date economice

| anul | VNA(mii e... |
|------|-------------------|
| 1 | an PIF -174000.14 |
| 2 | 1.0 -142432.42 |
| 3 | 2.0 -112367.94 |
| 4 | 3.0 -83735.09 |
| 5 | 4.0 -56465.71 |
| 6 | 5.0 -30494.87 |
| 7 | 6.0 -5760.74 |
| 8 | 7.0 17795.57 |
| 9 | 8.0 40230.16 |
| 10 | 9.0 61596.43 |
| 11 | 10.0 81945.26 |
| 12 | 11.0 101325.1 |
| 13 | 12.0 119782.09 |
| 14 | 13.0 137360.17 |
| 15 | 14.0 154101.2 |
| 16 | 15.0 170045.04 |
| 17 | 16.0 172360.32 |
| 18 | 17.0 174565.34 |
| 19 | 18.0 176665.37 |
| 20 | 19.0 178665.39 |
| 21 | 20.0 180570.17 |

cost parc [mii euro]

174000

putere act. [kW]

100000

pret integral/Mwh

252

energie an [MWh]

140461

Venit/an/15ani [mii

33146.1

suprafata [mp]

2.0125e+006

RIR [%]

18.4

nr panouri

416667

recuperare [ani]

5.25

recuperare actualiz [ani]


6.24

Octavian Capatina

Inapoi

10-Oct-2011

Parc solar cu orientare fixa, VNA, RIR, Rol




Put. parc kW: 100000 locatie: Feleac lat: lon: R.solara: 3.85 modul solar: scheutenP250 Put ms W: 250 arie ms mp: 1.82 efic. ms %: 13.73

Cost echip. 1.5 euro/w % instalare 6 din valoarea panourilor % O&M 1.5 cost autoriz. 0.15 euro/w durata pr 20 rata actualiz 5 pret MWh 52 pret CV 50 nr CV 6

Tiparire

Generare

x 10⁵ VNA(mii euro) la o rata de actualizare = 5%



Date economice

| anul | VNA(mii e... |
|------|-------------------|
| 1 | an PIF -174000.87 |
| 2 | 1.0 -129055.65 |
| 3 | 2.0 -86250.68 |
| 4 | 3.0 -45484.04 |
| 5 | 4.0 -6658.67 |
| 6 | 5.0 30317.87 |
| 7 | 6.0 65533.63 |
| 8 | 7.0 99072.44 |
| 9 | 8.0 131014.17 |
| 10 | 9.0 161434.86 |
| 11 | 10.0 190406.95 |
| 12 | 11.0 217999.42 |
| 13 | 12.0 244277.96 |
| 14 | 13.0 269305.14 |
| 15 | 14.0 293140.54 |
| 16 | 15.0 315840.93 |
| 17 | 16.0 318156.23 |
| 18 | 17.0 320361.27 |
| 19 | 18.0 322461.31 |
| 20 | 19.0 324461.34 |
| 21 | 20.0 326366.14 |

cost parc [mii euro]

174001

putere act. [kW]

100001

pret integral/Mwh

352

energie an [MWh]

140462

Venit/an/15ani [mii

47192.5

suprafata [mp]

2.18401e+006

RIR [%]

26.89

nr panouri

400002

recuperare [ani]

3.69

recuperare actualiz [ani]

4.18

Octavian Capatina

Inapoi

10-Oct-2011


Parc solar cu urmarire, locatie, VNA, RIR, RoI



Put. parc kW: 1000 locatie: Brasov lat: lon: R.solara: 3.5
 modul solar: GNGP295 Put ms W: 295 arie ms mp: 1.94 efic. ms %: 15.2
 Cost echip. euro/w: 1.7 % instalare: 0.5 % O&M: 7 cost autoriz.: 1.5 0.15
 panou, invertor s.urmarire din valoarea panourilor euro/w
 durata pr: 20 rata actualiz: 5 pret MWh: 52 pret CV: 57 nr CV: 6

Tiparire

Generare



Date economice

| anul | VNA(mii e... |
|----------|--------------|
| 1 an PIF | -2504.13 |
| 2 | 1.0 -1912.6 |
| 3 | 2.0 -1349.24 |
| 4 | 3.0 -812.71 |
| 5 | 4.0 -301.73 |
| 6 | 5.0 184.92 |
| 7 | 6.0 648.39 |
| 8 | 7.0 1089.8 |
| 9 | 8.0 1510.19 |
| 10 | 9.0 1910.55 |
| 11 | 10.0 2291.86 |
| 12 | 11.0 2655.0 |
| 13 | 12.0 3000.85 |
| 14 | 13.0 3330.24 |
| 15 | 14.0 3643.93 |
| 16 | 15.0 3942.69 |
| 17 | 16.0 3967.12 |
| 18 | 17.0 3990.39 |
| 19 | 18.0 4012.55 |
| 20 | 19.0 4033.65 |
| 21 | 20.0 4053.75 |

PARC SOLAR


cost parc [mii euro]: 2504.13 putere act.[kW]: 1000.05
 pret integral/Mwh: 394 energie an [MWh]: 1660.16
 Venit/an/15ani [mii euro]: 621.101 suprafata [mp]: 28938
 RIR [%]: 24.49 nr panouri: 3390
 recuperare [ani]: 4.03
 recuperare act [ani]: 4.62

Octavian Capatina

Inapoi

10-Oct-2011

INVERTOARE



Selectie

D-foss3k-265

RefuS4k8-525

SMA3k-300

ULX1k8-265

Victron5k-48

RefuS5k-529

inv-SI5k-48

Tiparire

| modulul | putere [W] | Ui min [V] | Ui max [V] | Ue | THD[%] | fr [Hz] | rand [%] | euro/w |
|----------------|------------|------------|------------|-------|--------|---------|----------|--------|
| 1 D-foss3k-... | 2.7 | 180.0 | 350.0 | 230.0 | 5.0 | 50.0 | 92.9 | 0.5 |
| 2 RefuS4k8... | 4.9 | 350.0 | 710.0 | 230.0 | 1.0 | 50.0 | 96.8 | 0.3 |
| 3 SMA3k-300 | 2.7 | 200.0 | 400.0 | 230.0 | 0.0 | 50.0 | 94.4 | 0.5 |
| 4 ULX1k8-265 | 1.8 | 180.0 | 350.0 | 230.0 | 3.0 | 50.0 | 91.6 | 0.3 |
| 5 Victron5k... | 5.0 | 38.0 | 66.0 | 230.0 | 0.0 | 50.0 | 95.0 | 0.252 |
| 6 RefuS5k-... | 5.06 | 349.0 | 710.0 | 230.0 | 1.0 | 50.0 | 97.4 | 0.25 |
| 7 inv-SI5k-48 | 5.0 | 41.0 | 63.0 | 230.0 | 3.0 | 50.0 | 95.0 | 0.7 |

Ordonare dupa putere

| modulul | putere [W] | Ui min [V] | Ui max [V] | DUI/UI max | Ue | THD[%] | fr [Hz] | rand [%] | euro/w |
|----------------|------------|------------|------------|------------|-------|--------|---------|----------|--------|
| 1 ULX1k8-265 | 1.8 | 180.0 | 350.0 | 49.0 | 230.0 | 3.0 | 50.0 | 91.6 | 0.3 |
| 2 D-foss3k-... | 2.7 | 180.0 | 350.0 | 49.0 | 230.0 | 5.0 | 50.0 | 92.9 | 0.5 |
| 3 SMA3k-300 | 2.7 | 200.0 | 400.0 | 50.0 | 230.0 | 0.0 | 50.0 | 94.4 | 0.5 |
| 4 RefuS4k8... | 4.9 | 350.0 | 710.0 | 51.0 | 230.0 | 1.0 | 50.0 | 96.8 | 0.3 |
| 5 Victron5k... | 5.0 | 38.0 | 66.0 | 42.0 | 230.0 | 0.0 | 50.0 | 95.0 | 0.252 |
| 6 inv-SI5k-48 | 5.0 | 41.0 | 63.0 | 35.0 | 230.0 | 3.0 | 50.0 | 95.0 | 0.7 |
| 7 RefuS5k-... | 5.06 | 349.0 | 710.0 | 51.0 | 230.0 | 1.0 | 50.0 | 97.4 | 0.25 |

Inapoi

SC IPA sucursala Cluj Napoca
 Str. Zorilor nr 15 CP 400435
 Tel 0264-596155
 Fax 0264-590558

Octavian Capatina
 0745-106900
oct.capa@gmail.com